



Office of the Sub Divisional Engineer,
Water Supply & Sanitation Sub Division Malout
Distt. Sri Muktsar Sahib.
E-mail:- sdo_malout123@yahoo.com

No. 220.....

Date. 10.12.2024

Sanitary Condition Certificate

It is certified that JRM WORLD SCHOOL Block Malout. Distt. Sri Muktsar Sahib has well continuous safe drinking water supply and has sufficient number of well maintained toilets and urinals.

The sanitary conditions of above said school are good.

Note:- This Certificate valid for only one year.

Sub Divisional Engineer,
W/S & Sanitation Sub Division,
Malout

JRM WORLD SCHOOL
PRINCIPAL

JRM WORLD SCHOOL
MANAGER

JRM WORLD SCHOOL
CHAIRMAN

BLOCK WATER TESTING LABORATORY, MALOUT

Water Supply & Sanitation Sub Division 3, BSNL Exchange Road, Malout
blwtlmalout@gmail.com

To,

Principal, JRM World School, Jandwala
JRM World School, Malout Bathinda Road, VPO-Jandwala

No.: BWTL/MLT/2425/00098 Dated : 02/12/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. JRMWS/2024-25/20 Dated: 29/11/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 29/11/2024. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Malout

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Malout

JRM WORLD SCHOOL

PRINCIPAL

JRM WORLD SCHOOL

MANAGER

JRM WORLD SCHOOL

CHAIRMAN

BLOCK WATER TESTING LABORATORY, MALOUT

Water Supply & Sanitation Sub Division 3, BSNL Exchange Road, Malout
blwtmalout@gmail.com

TEST REPORT

Name & Address of Customer : Principal, JRM World School, Jandwala JRM World School, Malout Bathinda Road, VPO- Jandwala	Customer Reference No.	No : JRMWS/2024-25/20 Dated : 29/11/2024	
	Sample Submitted by	Dilpreet Singh	
	Date of Sample Receipt	29/11/2024	
	Analysis Starting Date	29/11/2024	
	Analysis completion Date	02/12/2024	
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC000124000000101F	Sample Type :	Treated Water
Test Report No.:	BWTL/MLT/2425/00098	Date of Issue :	02/12/2024
Registration no.:	BWTL/MLT/REG2425/00332	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	500 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	JRM World School, Jandwala / NA
Village :	Jandwala Charat Singh	Habitation :	Jandwala Charat Singh
Block:	Malout	District :	Muktsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.96	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	160	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.52	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	36	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	16	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	3	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	2	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	34	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Block Water Testing Laboratory
Malout

End of the Test Report

JRM WORLD SCHOOL
PRINCIPAL

JRM WORLD SCHOOL
MANAGER

JRM WORLD SCHOOL
CHAIRMAN
Page No : 1/1